

Date : 7-10-2009  
 Référence : CA076-DB9  
 Révision : 01  
 Auteur : F. Vin

<b>Esco Code</b>	CA076-DB9
<b>Description</b>	Cable between UniOP with DB9 PLC port and Télémécanique TSX07 or Twido, Idec Micro3 PLC
<b>Communication Type</b>	RS-485
<b>PLC side connector</b>	Type Mini-DIN8P
<b>UniOP side connector</b>	Type Sub-D 9M (male)
<b>Notes</b>	1) For EscoView, eTOPxxCP & eTOP30X panels 2) For Twido controllers, when using port 1, the DPT signal (pin 5) must be tied to GND (pin 7).

Table 1. Cable Description between UniOP with DB9 and TSX07, Twido and Micro3 PLC

