


Date : 20-06-2010  
 Référence : CA096-DB9  
 Révision : 02  
 Auteur : F. Vin

<b>Esco Code</b>	CA096-DB9
<b>Description</b>	Cable between UniOP with DB9 PLC port and Siemens S7-200 PPI port
<b>Communication Type</b>	RS-485 (communication port setting = "Half Duplex (Normal)")
<b>PLC side connector</b>	Type Sub-D 9M (male)
<b>UniOP side connector</b>	Type Sub-D 9M (male)
<b>Notes</b>	For EscoView, eTOPxxCP & eTOP30X panels with TCA11 board

Table 1. Cable Description between UniOP with DB9 and Siemens S7-200 PPI port



**ATTENTION !**

- both connectors are DB9 Male
- It's important to mark PLC and UniOP sides
- Cable inversion may cause damages on PLC and UniOP communication ports !!